

RAPPORT DE TEST DE GRADATION 0-10V

DIMMING TEST REPORT 0-10V



Power Supply: LTPS-DIM-0-10V-110-277VAC-CV-24V-100W-HW-IP66 @ MIN. LOAD

Manufacturer	Model	Bypass (without dimmer)		Power (W)		Current (A)		Dimming (%)	
		Power (W)	Current (A)	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum
Leviton	DD 710			1.528	0.137	0.067	0.001	93.97%	8.97%
Leviton	AWSMT-7DW			1.520	0.162	0.062	0.020	93.48%	10.66%
Leviton	DS 710			1.536	0.013	0.063	0.005	94.46%	0.85%
Legrand	WS4FBL3P	1.626	0.08	1.432	0.019	0.610	0.006	88.07%	1.33%
Legrand	RH4FBL3PTC			1.516	0.046	0.062	0.010	93.23%	3.03%
Lutron	DIVA DSCTV			1.515	0.032	0.062	0.008	93.17%	2.11%
Lutron	NOVA NTSTV DV			1.516	0.039	0.062	0.009	93.23%	2.57%

Power Supply: LTPS-DIM-0-10V-110-277VAC-CV-24V-100W-HW-IP66 @ MAX. LOAD

Manufacturer	Model	Bypass (without dimmer)		Power (W)		Current (A)		Dimming (%)	
		Power (W)	Current (A)	Maximum	Minimum	Maximum	Minimum	Maximum	Minimum
Leviton	DD 710			51.25	6.946	2.123	0.771	97.94%	13.55%
Leviton	AWSMT-7DW			51.20	5.36	2.122	0.675	97.84%	10.47%
Leviton	DS 710			51.54	1.195	2.134	0.310	98.49%	2.32%
Legrand	WS4FBL3P	52.33	2.163	50.16	1.224	2.109	0.312	95.85%	2.44%
Legrand	RH4FBL3PTC			50.76	0.374	2.111	0.167	97.00%	0.74%
Lutron	DIVA DSCTV			51.36	0.789	2.126	0.248	98.15%	1.54%
Lutron	NOVA NTSTV DV			51.23	1.183	2.121	0.307	97.90%	2.31%